

項目		水溫	PH	COD	SS	氨氮	油脂	銅	鎳	總鉻	鋅	硝酸鹽氮	氟鹽	陰離子界面活性劑	六價鉻	錫	水量
檢測標準	2021	38°C ↓ (5月-9月) 35°C ↓ (10月-4月)	6.0-9.0	100	30	20	10	1.5	0.7	1.5	3.5	50	15	10	0.35	2	LK:263.77 TL:180
	2022	°C ↓ (5月-9月) °C ↓ (10月-4月)	6.0-9.0	100	30	20	10	1.5	0.7	1.5	3.5	50	15	10	0.35	2	LK:263.77
	2023	°C ↓ (5月-9月) °C ↓ (10月-4月)	6.0-9.0	100	30	20	10	1.5	0.7	1.5	3.5	50	15	10	0.35	2	LK:255
單位		°C	-	mg/L													CMD
LK	2021/Q2	32.5	7.6	83	5	0.05	1.2	0.09	ND	0.1	0.01	ND	0.14	0.83	ND	ND	224.75
	2021/Q4	25.6	7.3	75.9	8.2	0.05	3	0.4	ND	ND	ND	0.34	0.11	0.75	ND	ND	264.98
	2022/Q1	15.2	8.4	59.1	5.4	0.05	1.6	0.73	ND	ND	ND	0.1	0.14	0.72	ND	ND	231.11
	2022/Q3	30.6	8.2	48	5.2	0.06	2.5	ND	ND	ND	ND	ND	0.2	0.65	ND	ND	228.54
	2023/Q1	18.4	7.4	51.4	14.5	0.06	1	0.53	ND	ND	ND	0.49	0.1	2.16	ND	ND	207.1
	2023/Q3	29.8	7.9	24.2	14.3	0.06	1.4	0.82	ND	ND	ND	0.25	0.1	1.79	ND	ND	209.2
TL	2021/Q2	23.4	8.1	37.6	9.6	0.02	5.8	0.84	ND	ND	0.02	4.64	0.16	2.05	ND	ND	159
	2021/Q4	20.6	7.6	21.5	9.7	0.01	-	0.32	ND	ND	ND	2.47	0.23	-	-	-	130
	2022/Q2	24.6	8	31	18.8	ND	-	0.45	ND	ND	<0.01	4.51	3.6	-	ND	ND	112
	2022/Q4	21.5	7.7	73.5	26.9	0.09	-	0.58	ND	ND	0.13	0.91	0.45	-	-	-	172
	2023/Q2	31.4	7.4	34.4	14.8	0.3	-	0.6	ND	ND	0.08	2.6	1.64	-	ND	ND	74
	2023/Q4	25.9	7.8	28	29	0.01	-	1.21	ND	0.02	0.02	7.02	10.5	-	-	-	174

- 註：1. 由於工廠製程性質不同，所檢測之項目與頻率不盡相同，此表檢測項目為共同項目之部分擷取，本公司檢測之項目與頻率皆符合主管機關水汙染防治法規規範。
- 2. 兩廠最高廢水放流量449.77CMD=林口廠269.77CMD+銅鑼廠180CMD